





## State Water Resources Control Board

June 30, 2015

CERTIFIED MAIL NO. 7014 2120 0000 5508 3545

Mr. Lewis Broschard Assistant Chief Contra Costa County Fire Protection District 2010 Geary Road Pleasant Hill, California 94523

SUBJECT:

NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS LOCATED AT CONTRA COSTA COUNTY FIRE PROTECTION DISTRICT,

STATION #14, 521 JONES STREET, MARTINEZ

Dear Mr. Broschard:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on June 4, 2015, pursuant to authority under Health and Safety Code, chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to Health and Safety Code (H&SC), chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Facility and Tank Information (A&B Forms) - Change piping system to conventional suction and update tank installation date and manufacturer.	Diesel	June 4, 2015	June 15, 2015	23 CCR 2711(a)
2	Failure to Maintain Monitoring Plan - Update person having responsibility, pipe monitoring, monitor panel manufacturer, leak sensor model #, and recordkeeping section for Tank Integrity Testing Results to "No."	Diesel	June 4, 2015	Ongoing	23 CCR 2711(a)(9)
3	Failure to Maintain Release Response Plan – Update person having responsibility.	Diesel	June 4, 2015	Ongoing	23 CCR 2632(d)(2)

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	Failure to Provide DO Training - The employee training record performed by the DO is dated March 27, 2014.	Diesel	April 1, 2015	Ongoing	23 CCR 2715(f)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Contra Costa County Health Services within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

## State Water Board

Ms. Rebecca Green **UST Enforcement Unit** State Water Resources Control Board 1001 I Street, 19th Floor Sacramento, California 95814 rebecca.green@waterboards.ca.gov

## Local CUPA

Ms. Alexandra McMullen Supervising Administrative Support Contra Costa County Health Services Department 4585 Pacheco Boulevard, Suite 100 Martinez, California 94553 alexandra.mcmullen@hsd.cccounty.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me by telephone at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel

Senior Environmental Scientist

**UST Enforcement Unit** 

Office of Enforcement

cc: (via email only)

Ms. Alexandra McMullen Supervising Administrative Support Contra Costa County Health Services Department alexandra.mcmullen@hsd.cccounty.us

Mr. Adam Springer Hazardous Materials Specialist II Contra Costa County Health Services Department Adam.Springer@hsd.cccounty.us